



NOTES

1. 1" SERVICE SHALL BE COPPER TYPE "K" SOFI.
2. SPLICES IN THE SERVICE LINE ARE TO BE AVOIDED, BUT WHERE APPROVED, THEY SHALL BE MADE USING CTS GRIP-TYPE COMPRESSION COUPLING.
3. ALL FITTINGS ARE COPPER OR BRASS AND SHALL BE MUELLER 110 (CONDUCTIVE TYPE) COMPRESSION CONNECTIONS OR CITY APPROVED EQUAL.
4. WHEN BACKFLOW PREVENTER IS REDUCED, SEE DETAIL W10.
5. ROCK BOTTOM OF BOX WITH 3" MIN OF 3/4" MINUS CRUSHED ROCK.
6. PACK JOINT FITTINGS ARE NOT ACCEPTABLE

CHRISTY		
CONDITION	MODEL NO.	TYPE
CONCRETE	B-36	STEEL-36 W/ PROBE HOLE
LAWN/LANDSCAPE	B-36	FIBERUTE-36 W/ PROBE HOLE

<p>City of Woodlake Improvement Standards</p>		<p>Date: <u>November 14, 2005</u></p>	<p>Standard No.</p>
<p>1" DUAL WATER SERVICE</p>	<p>Revisions</p>	<p>_____ City Engineer</p>	